



717-2008 ADDENDUM #1

Supply and Delivery of Diesel Generator and Transfer Switch

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 8, 2008
BY: Chris Hewitt, P.Eng
TELEPHONE NO. (204) 789 2342

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.1

The Work to be done under the Contract shall consist of supply and delivery of a diesel generator **(including supply of 2400 litres of fuel, and top up of fuel used during commissioning)** and transfer switch, including all start-up testing, commissioning, training and coordination with General Contractor.

PART E – SPECIFICATIONS

Revise: E2.2.2 (vii)

Fuel supply system **to include all generator set mounted fuel equipment such as pumps, filters etc. Supply and installation of bulk storage tank, day tank, main fuel transfer pumps and piping will for part of General Contractor's scope of work.**