

NOTES:

## CONSTRUCTION NOTES

1 Remove existing cables feeding existing lights back to panelboard. Remove existing lights. Return cables and lights to owner. Coordinate exact location of lights with other diciplines.

2 Boiler emergency disconnect switch for B-3 and B-4.

(5) Install receptacles at 2275 AFF

3 Remove card swipe system prior to demolition and reinstall after installation of new door and wall.

Relocate switches as shown prior to wall demolition. 

for Type C lighting. Refer to specs for height of other receptacles. 6 Remove all existing communications

cabling in their entirety from new mechanical and electrical room back to the distribution source.

Remove existing feed cable for exhaust fan back to source. Refeed from B100.

8 Connect fire alarm to existing fire alarm

(9) Connect all equipment ground to ground bar using insulated grounding conductors. Refer to Detail 3 for ground bar details. Refer to specs for insulated grounding conductors details.

~~~~~<del>~</del>

ISSUED FOR ADDENDUM 4 ISSUED FOR ADDENDUM 2 **ISSUED FOR ADDENDUM 1** REVISION/DESCRIPTION

## EARTH TECH | AECOM

DL CHECKED BY APPROVED 2009.01.06 USER APPROVAL



PROJECT

CITY OF WINNIPEG PLANNING, PROPERTY AND DEVELOPMENT DEPARTMENT CIVIC ACCOMMODATIONS DIVISION 300 - 65 GARRY ST. R3C 4K4

SHEET NO.

CONFEDERATION BUILDING SUPPLEMENTARY HEATING UPGRADES PHASE 1 - CITY BID OPP. NO. 757-2008

457 MAIN STREET, WINNIPEG, MANITOBA

SHEET TITLE

AS SHOWN

BASEMENT LEVEL

SCALE

**APEGIN** 

**Certificate of Authorization** 

Earth Tech Canada Inc.

No. 730 Expiry: April 30, 2009

© 2008 EARTH TECH (CANADA) INC. ALL RIGHTS RESERVED. THIS DOCUMENT IS PROTECTED BY COPYRIGHT LAW AND MAY NOT BE USED, REPRODUCED OR MODIFIED IN ANY MANNER OR FOR ANY PURPOSE EXCEPT WITH THE WRITTEN PERMISSION OF EARTH TECH (CANADA) INC. DOING BUSINESS AS AECOM ("AECOM") OR A PARTY TO WHICH ITS COPYRIGHT HAS BEEN ASSIGNED. AECOM ACCEPTS NO RESPONSIBILITY, AND DENIES ANY LIABILITY WHATSOEVER, TO ANY PARTY THAT USES, REPRODUCES, MODIFIES, OR RELIES ON THIS DOCUMENT WITHOUT AECOM'S EXPRESS WRITTEN CONSENT.

SADLER

Member

30812

A 8 B 100 10

**ELECTRICAL ROOM LAYOUTS** PROJECT NO.

DRAWING SHEET SIZE: A1 (841mm x 594mm) PLOT 1:1