



ADDENDUM 4 BID OPPORTUNITY NO. 839-2008

SUPPLY, DELIVERY, INSTALLATION, AND COMMISSIONING OF
NATURAL GAS ENGINE DRIVE P26 AT THE MACLEAN PUMPING
STATION

ISSUED: January 6, 2009
BY: Claude Courchaine, P. Eng. -AECOM
TELEPHONE NO. (204) 928-7415 or 284-0580

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF BID
OPPORTUNITY**

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

Clarification

1. Regarding Natural Gas Supply.

As stated in the original Bid Opportunity documents, if the specified engine requires a greater gas pressure than the available 4.9 psig, the Contractor is responsible to provide all additional applications, permits, inspections, material, resources, and any items not already specified in the Bid Opportunity documents, as may be required to provide the greater gas pressure to the new engine.

Manitoba Hydro has previously confirmed that a maximum natural gas pressure of 30 psig is available at the meter. The Manitoba Hydro contact is Brian Adamyk at 477-7715.

END OF ADDENDUM 4