


SUPPLY AND INSTALL CONDUIT TO SHELTER SUPPORT SAWCUT, BREAKOUT AND REMOVE SECTION OF EXISTING CONCRETE BASE POUR CONCRETE AROUND CONDUIT AND JUNCTION BOX AFTER FINAL CONNECTIONS AND TESTING -SUPPLY AND INSTALL WEATHER PROOF JUNCTION BOX FLUSH TO GRADE -EXISTING POWER CONNECTION FOR RADIANT HEATERS **SECTION** -EXISTING POWER CONNECTION FOR SHELTER LIGHTING

<u>PLAN</u>



JUNCTION BOX DETAIL FOR ELECTRICAL CONNECTION OF RADIANT HEATERS ON EXISTING SHELTER BASES SHOWN FOR INFORMATION CONTRACTOR TO COORDINATE WITH ELECTRICAL CONTRACTOR FOR INSTALLATION OF WIRING. DO NOT INSTALL GLAZING IN SHELTER UNTIL ALL ELECTRICAL CONDUIT HAS BEEN REROUTED AS REQUIRED TO MEET ELECTRICAL CODE.



WINNIPEG TRANSIT

SUPPLY & INSTALLATION OF ILLUMINATED TRANSIT SIGNS & TRANSIT PASSENGER SHELTERS

ELECTRICAL
CONNECTION DETAIL
Project No.
06-029

Drowing No.
TS-4