



609-2009 ADDENDUM 3

WATER PUMPING STATIONS ELECTRICAL INSPECTIONS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 15, 2009
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Clarification of E9.3(k)(i), E10.3(l)(i), E11.3(m)(i):

Inspect each of the generator natural gas engines and fuel systems as per CSA C282.
Mechanical inspection work is included in the scope of work.