



740-2009 ADDENDUM 2

CITY OF WINNIPEG FORT ROUGE TRANSIT GARAGE - VEHICLE EXHAUST UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 27, 2009
BY: Peter Gryc, M.Sc., P.Eng., LEED AP.
TELEPHONE NO. (204) 775-0291

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Section 16192 – Mechanical Equipment Connections

Clause 1.2 System Description

Add Item 1.2.2 to read: "Division 16 shall have the manufacturer's representative of the existing Motor Control Centre visit the site to determine any modifications required to the existing Westinghouse Motor Control Centre to accept the installation of the new motor starters. Division 16 shall include any required modifications in their bid price."