



740-2009 ADDENDUM 3

CITY OF WINNIPEG FORT ROUGE TRANSIT GARAGE - VEHICLE EXHAUST UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: December 1, 2009
BY: Peter Gryc, M.Sc., P.Eng., LEED AP.
TELEPHONE NO. (204) 775-0291

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Section 16192 – Mechanical Equipment Connections

Clause 1.2 System Description

Revise Item 1.2.2 to read: "Division 16 shall connect new motors to existing motor starters in existing motor control. centre. Install new applicable overloads in existing starters as required for new motors."