



120-2010 ADDENDUM 1

Supply and Installation of an Underground Fuel Storage Tank and All Associated Equipment at 1220 Pacific Avenue

ISSUED: March 4, 2010
BY: Ajaleigh Williams
TELEPHONE NO. (204) 986-7879

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph ^ of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B10.3 (d) The Bidder shall be a Licensed Petroleum Technician (LPT) for any work regulated by the Province of Manitoba, requiring a Licensed Petroleum Technician for specific Work functions.

PART E – SPECIFICATIONS

Revise: E2.2 Retrofit and Install Fuel Dispensers Supplied by the City.

Revise: E2.2(a) Retrofit and installation of two (2) fuel pumps and dispensers in compliance with all applicable regulations and permit requirements. Retrofitted dispensers shall meet the following specifications:

Revise: E2.2 (a) (i) Compatible with E10, unleaded gasoline and marked gasoline.

Revise E2.2 (a) (iii) Fuel dispensers shall be supplied by the City and shall be Gilbarco legacy commercial models JC1100 (gas) with electronic register TYPE Eliminator 6.0.