



120-2010 ADDENDUM 3

Supply and Installation of an Underground Fuel Storage Tank and All Associated Equipment at 1220 Pacific Avenue

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 15, 2010
BY: Ajaleigh Williams
TELEPHONE NO. (204) 986-7879

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E2.1 (a) (xi) to read: A 250 mm reinforced concrete slab shall be placed over the storage tank and fuelling area as shown on drawing # 207-001-S1. The slab shall be graded in conformance with the drawing and shall be directly tied into the existing concrete pad with tie bar supports. Concrete slab shall conform to specifications in E2.9. All work associated with the installation of the drilled tie bars shall be incidental to the cost of placing 250mm of reinforced pavement. The drilled tie bars shall be 20M deformed.
- Revise: E2.1 (a) (xii) to read: Placement of the Asphalt surfacing material will be completed by others.