

1 BASEMENT FLOOR PLAN - LIGHTING LAYOUT
El2.0 SCALE: 1:100

NOTES:

- 1. OCCUPANCY SENSORS THIS DRAWING SHALL BE INSTALLED C/W MINIMUM #10 GAUGE WIREGUARD UNLESS NOTED OTHERWISE.
- 2. REFER TO OCCUPANCY SENSOR SCHEDULE FOR SENSOR SPECIFICATIONS AND TYPES.
- 3. PROVIDE SINGLE POLE TOGGLE SWITCH TO CONTROL CORRIDOR LIGHTING DENOTED BY CIRCUIT A-2. PROVIDE LAMACOID NAMEPLATE INDICATING SAME.
- 4. MOUNTED IN PIT.
- 5. EXPOSED WIRING SHALL BE INSTALLED IN EMT CONDUIT.
- 6. TYPE 'FO8' AND 'F09' LUMINAIRES SHALL BE INSTALLED C/W CUSTOM MINIMUM #10 WIREGUARD.



APEGIN Certificate of Authorization MCW/AGE Consulting Professional Engineers

No. 589 Expiry: April 30, 2010

D ISSUED FOR TENDER C ISSUED FOR 99% REVIEW B ISSUED FOR 90% REVIEW

FEB 10, 2010 **JAN** 08, 2010 A ISSUED FOR 60% REVIEW DEC 02, 2009

FEB 26, 2010

This drawing must not be scaled.

The general Contractor must verify all dimensions, datums and levels prior to commencement of work. All errors and omissions must be reported immediately to the Architect.

Variations and modifications to work shown on this drawing shall not be carried out without written permission from the Architect.

This drawing is the exclusive property of the Architect and cannot be reproduced without written permission of the Architect. Reproduction must bear the name of the Architect. Copyright © 2009.



MCW / AGE

Consulting Professional Engineers
210-1821 Wellington Avenue
Winnipeg, Manitoba, R3H 0G4
Phone - (204) 779-7900 Fax - (204) 779-1119
E-Mail: mcw_wpg@mcw.com



SINCLAIR COMMUNITY CENTRE **ADDITION & RENOVATIONS**

490 Sinclair Street, Winnipeg

sheet title

BASEMENT LIGHTING LAYOUT

project number: 5878

P.A.S. approved by: K.B.G. 2010-02-26