

1 MAIN FLOOR PLAN - LIGHTING LAYOUT
EL2.1 SCALE: 1:100

## NOTES:

- 1. OCCUPANCY SENSORS THIS DRAWING SHALL BE INSTALLED C/W MINIMUM #10 GAUGE WIREGUARD UNLESS NOTED OTHERWISE. AREAS TO BE EXCLUDED ARE BOARDROOM M05 AND OFFICE M04.
- 2. REFER TO OCCUPANCY SENSOR SCHEDULE FOR SENSOR SPECIFICATIONS AND TYPES.
- 3. PROVIDE SINGLE POLE TOGGLE SWITCH TO CONTROL CORRIDOR LIGHTING DENOTED BY CIRCUITS A-21. PROVIDE LAMACOID NAMEPLATE INDICATING SAME.
- 4. PROVIDE GYM LIGHTING CONTROL PANEL MANUFACTURED BY JR STEPHENSON OR APPROVED EQUAL. REFER TO DETAIL 1/E6.2.
- 5. OCCUPANCY SENSOR SHALL BE INSTALLED SUCH THAT DIMMING CONTROL IS STILL UTILIZED FOR LIGHT LEVEL CONTROL. OCCUPANCY SENSOR SHALL OVERRIDE DIMMER CONTROL
- 6. PROVIDE TWO(2) SAFETY CHAINS, ONE(1) PER EACH END, FOR TYPE 'F06' AND 'F07' LUMINAIRES.
- 7. TYPE 'F08' AND 'F09' LUMINAIRES SHALL BE INSTALLED C/W MINIMUM #10 WIREGUARD.



Certificate of Authorization
MCW/AGE Consulting
Professional Engineers
No. 589 Expiry: April 30, 2010

FEB 26, 2010

FEB 10, 2010

JAN 08, 2010

DEC 02, 2009

D ISSUED FOR TENDER
C ISSUED FOR 99% REVIEW
B ISSUED FOR 90% REVIEW

A ISSUED FOR 60% REVIEW

This drawing must not be scaled.

The general Contractor must verify all dimensions, datums and levels prior to commencement of work. All errors and omissions must be reported immediately to the Architect.

Variations and modifications to work shown on this drawing shall not be carried out without written permission from the Architect.

This drawing is the exclusive property of the Architect and cannot be reproduced without written permission of the Architect. Reproduction must bear the name of the Architect. Copyright © 2009.



MCW / AGE

Consulting Professional Engineers
210-1821 Wellington Avenue
Winnipeg, Manitoba, R3H 0G4
Phone - (204) 779-7900 Fax - (204) 779-1119
E-Mail: mcw\_wpg@mcw.com



project

SINCLAIR COMMUNITY
CENTRE
ADDITION & RENOVATIONS
490 Sinclair Street, Winnipeg

sheet title

MAIN FLOOR LIGHTING LAYOUT

project number: 5878 drawing number:
scale: N.T.S.
drawn by: P.A.S.
approved by: K.B.G.

2010-02-26