



413-2010 ADDENDUM 1

2010 BRIDGE MAINTENANCE – ST. VITAL BRIDGE APPROACH PAVEMENT WORKS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 4, 2010
BY: Mark Doucet
TELEPHONE NO. (204) 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E9.2.2 to read: GFRP Reinforcing

- (a) ASLAN 100 by Hughes Brothers,
- (b) Pultrall V-Rod, or approved equal in accordance with B5.