



428-2010 ADDENDUM 1

INSTALLATION OF BOILERS AT 457 MAIN STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 22, 2010
BY: Ding Chan, P.Eng.
TELEPHONE NO. (204) 477-5381

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D3.1 to read: The City will supply the following equipment and material:

- (a) two (2) condensing boilers (Units B-1 & B-2): CAMUS HYDRONIC LTD. - DynaForce 1400;
- (b) two (2) hydronic pumps (Units P-5 & P-6): PATTERSON PUMP COMPANY - 5885-95;
- (c) one (1) hydronic pump (Units P-14): WILO CANADA INC. - MVI 50-03 3~; and
- (d) two (2) indirect water heaters (Units IWH-1 & IWH-2): THERMO 2000 INC. - TURBOMAX 65.