

250 COUPLING —

STREET

REMOVE 45° BEND. CONNECT TO EXISTING

250 PVC WM

4.877

NOTE:

CHAINAGE IS ALONG EAST PROPERTY LINE OF HUGO STREET

NOTE:

HUGO STREET, FROM FLEET AVE TO WARSAW AVE, IS PART OF 2010 PAVEMENT RENEWAL PROJECT. FINAL SURFACE RESTORATION OF PAVEMENTS, BOULEVARDS, AND SIDEWALKS EXCAVATED FOR WATERMAIN AND SEWER RENEWAL CONSTRUCTION IN THIS PORTION OF HUGO STREET WILL BE CARRIED OUT BY THE PAVEMENT RENEWAL CONTRACTOR.

CONSTRUCTION NOTES

- 1. WATERMAIN TO HAVE 2.5m COVER FROM CENTRELINE OF ROAD.
- 2. ALL CURB REPLACEMENT TO MATCH EXISTING CURB.
- ALL EXISTING WATERMAINS AT CONNECTION LOCATIONS ARE TO HAVE INVERTS VERIFIED PRIOR TO CONSTRUCTION.
- 4. INSTALL ALL HYDRANTS WITH FLANGE ELEVATION FROM 50mm TO 150mm ABOVE FINISHED GRADE.
- 5. SALVAGE ALL EXISTING HYDRANT ASSEMBLIES AND VALVES WHEN DIRECTED BY THE CONTRACT ADMINISTRATOR AND RETURN TO THE CITY YARD. ABANDON THE REMAINING VALVES (AND/OR VALVE BOXES) AND HYDRANT ASSEMBLIES.
- 6. INSTALL WATERMAIN BY TRENCHLESS METHODS UNDER ALL PAVEMENTS, TREES, LIGHT STANDARDS, AND OTHER APPURTENANCES.
- 7. RENEW ALL LEAD WATER CONNECTIONS UP TO THE PROPERTY LINE WITH 20mm COPPER WATER CONNECTIONS UNLESS RENEWAL SIZE IS OTHERWISE
- 8. ALL VALVES SHALL TURN COUNTER CLOCKWISE TO CLOSE WITH RED OPERATING NUT.
- 9. ALL BACKFILL UNDER PAVEMENT SHALL BE CLASS 3.
- 10. ALL BACKFILL UNDER BOULEVARD SHALL BE CLASS 5.
- 11. ABANDON SERVICES NO LONGER IN USE WHERE DIRECTED BY CONTRACT
- 12. CONTRACTOR TO NOTIFY BUSINESSES AND RESIDENTS A MINIMUM OF 24 HOURS PRIOR TO ANY DISRUPTION TO WATER SERVICE.

GENERAL NOTES

STATION 3+00 = SOUTH LIMIT OF FLEET AVENUE.

APEGIN Certificate of Authorization Wardrop Engineering Inc. No. 195 Expiry: April 30, 2011

| <u>150_WM</u> | WATERMAIN | | 凸 | TEE | 再 | \odot | TREE | |
|---------------|---------------------|----------|----------|----------------|----------|---------------------|-----------------|----------|
| 400_FM | FEEDERMAIN | | ď | CURB STOP | •, | 15.240 | LEGAL DIMENSION | |
| 300_LDS | LAND DRAINAGE SEWER | | | PLUG | | + | SURVEY BAR | |
| 250_WWS | WASTEWATER SEWER | | 0 | MANHOLE | • | — · – · • • · – · – | TRAFFIC SIGNAL | |
| 300_CS | COMBINED SEWER | | | CATCHBASIN | | | GAS | |
| 200_FCM | FORCEMAIN | | ▽ | CURB INLET | ▼ | | HYDRO | |
| | REDUCER | • | | ZINC ANODE | a | | ASPHALT | |
| | HYDRANT | + | • | HYDRO POLE | | | CURB | |
| 8 | VALVE | 8 | ••• | LIGHT STANDARD | | 66 | ADDRESS | |
| 4 | BEND | 4 | ← | ANCHOR | | | SIGN | |
| EXISTING | LEGEND-PLAN | PROPOSED | EXISTING | LEGEND-PLAN | PROPOSED | EXISTING | LEGEND-PLAN | PROPOSED |

HUGO

(300)

ABANDON EXIST

ABANDON EXISTING

└-`-250 PVC WM**-**

250 CI WM

350 CI WM

CHURCH

| | LOCATION APPROVED UNDERGROUND STRUCTURES |
|-----------|--|
| \exists | SUPV. U/G STRUCTURES DATE COMMITTEE |
| | NOTE: LOCATION OF UNDERGROUND STRUCTURES AS SHOWN ARE BASED ON THE BEST INFORMATION AVAILABLE. BUT NO GUARANTEE IS GIVEN THAT ALL EXISTING UTILITIES ARE SHOWN OR THAT THE GIVEN LOCATIONS ARE EXACT. CONFIRMATION OF EXISTENCE AND EXACT LOCATION OF ALL SERVICES MUST BE OBTAINED FROM THE INDIVIDUAL UTILITIES BEFORE PROCEEDING WITH CONSTRUCTION. |
| | |

Ν

7.20± 5.18±

10.06±

6.25

7.62

20.117

10.06±

4.67±

|) | B.I | M. EV. | | | | | |
|-----------------------|-----|---------------------|----------|-------------------------|--------------------|--|---|
| | | | | | WARDROP | PEOPLE, PASSION, PERFORMANCE. TRUSTED GLOBALLY | |
| - | | | | | ATETRATECH COMPANY | | ODICINIAL DRAWING |
| | | | | | DESIGNED GWC | CHECKED BLM | ORIGINAL DRAWING REVISION "00" SEALED BY B.L. McINTOSH, P. ENG. |
| | | | | | DRAWN BY NL | APPROVED GS BY | 2010.05.13 |
| | | | | | HOR. SCALE: 1:250 | RELEASED FOR | 1 |
| | 01 | ISSUED FOR TENDER | 10.05.14 | GS | | CONSTRUCTION | CONSULTANT DRAWING NO. |
| | 00 | ISSUED FOR APPROVAL | 10.05.13 | BLM | VERTICAL: 1:50 | | |
| NO. REVISIONS DATE BY | | DATE 10.03.23 | DATE | 1000120100-DWG-C0008-01 | | | |
| | | | | | | | |
| | | | | | | | |

2.13±

ABANDON EXIST

350 CI WM

– - — - — O/H HYDRO— - — -

NG NG

-350 CI WM-

-250 PVC WM-

4.57±

6.25



THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

2010 - WATERMAIN RENEWALS AND SEWER REHABILITATION

CONTRACT 11 HUGO STREET N

9m NORTH OF MULVEY AVENUE

TO 14m NORTH OF WARSAW AVENUE

| TY DRAWING NUMBER | | | | |
|-------------------|-------|--|--|--|
| D-12031 | | | | |
| HEET O | OF 40 | | | |
| 8 | 10 | | | |
| | | | | |
| C0008 | | | | |
| C0000 | | | | |