



457-2010 ADDENDUM 1

2010 WATERMAIN RENEWALS – CONTRACT 8

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 16, 2010
BY: James Hines
TELEPHONE NO. (204) 488-5703

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 457-2010 Bid Submission with 457-2010 Addendum 1 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Revise Item A14 (b)

PART D – SUPPLEMENTAL CONDITIONS

Revise: D14.1 (a) to read Construction of the Work at St. Mary's Road and Fernwood Avenue shall be completed within the first 15 Working Days of the project. All Work required to complete the renewal of the 300mm watermain through the intersection at Mary's Road and installation of 10 metres of 150mm pipe to the east of the proposed 150mm valve at the south east corner of Fernwood Avenue and St. Mary's Road must be completed in the first 15 Working Days. All testing and restorations shall also be completed within the first 15 Working Days.

Add: D14.1 (b) Construction of the Work on Pulberry Street shall be completed within the first 20 Working Days of the project. All testing and restorations shall also be completed within the first 20 Working Days of the project. The Contractor shall be required to leave the site to accommodate a street rehabilitation contract immediately following the watermain renewal.

PART E – SPECIFICATIONS

Add: E14.4 The Contractor shall use early opening concrete (24 hours) on St. Mary's Road for the partial slab patches in the road.