



## **BID OPPORTUNITY No. 476-2010 ADDENDUM No.1**

**2010 FEEDERMAIN INSTALLATION AND ASSOCIATED WORKS ON  
BISON DRIVE FROM WAVERLEY STREET TO KENASTON BOULEVARD  
– CONTRACT NO. 17**

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: June 21, 2010  
BY: Doug Berg, C.E.T.  
TELEPHONE NO. (204) 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

Revise E8.1.1 (a) (i) to read: PVC pipe shall conform to the latest revision of AWWA C905 and CSA B137.3-M86, with the following dimension ratios (DR)

- ◆ 750 millimetre DR 25

Add: E8.1.1 (a)(ii) Further to AWWA C905, 4.3.2.2 Elastomeric-gasket bell ends shall conform to the requirements of Section 4.3.2.2 (a). Designs not meeting the requirements of Sec.4.3.2.2 (a) will not be permitted

### **DRAWINGS**

Replace: Drawing D12119-R1 with Drawing D12119-R2