



557-2010 ADDENDUM #2

REPLACE LIGHTING ON POOL DECK – 999 SARGENT AVENUE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 28, 2010
BY: Kathy Roberts
TELEPHONE NO. (204) 470-7380

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Add: B3.1.1 Further to C3.1 and B3.1, the Contract Administrator or an authorized representative will be available at the Site from 10:00 a.m. to 11:00 a.m. on August 5, 2010 to provide Bidders access to the Site.

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.2(b)(iii): Contractor may assume that existing wiring at luminaire location at the Diving Platform (Drawing E-2, Note 4), terminates at a panel adjacent to the existing lighting panel. If investigation is required to trace out the wiring, it shall be a time and materials extra.

Revise: D2.2(c)(ii) to read: Contractor must arrange his Work such that at the end of each shift, lighting levels on the pool deck are never less than 200 Lx.

PART E – SPECIFICATIONS

Revise: E1.3 to read: The following are applicable to the Work:

<u>Drawing No.</u>	<u>Drawing Name/Title</u>
E-1 R1	SECOND FLOOR PLAN – DEMOLITION
E-2 R1	SECOND FLOOR PLAN – CONSTRUCTION
E-3 R1	MAIN FLOOR PLAN – CONSTRUCTION
E-4 R1	SPECIFICATIONS AND DETAILS

DRAWINGS

Replace: 557-2010 _Drawing_E-1 with 557-2010 _Addendum_#2 Drawing_E-1_R1

Replace: 557-2010 _Drawing_E-2 with 557-2010 _Addendum_#2 Drawing_E-2_R1

Replace: 557-2010 _Drawing_E-3 with 557-2010 _Addendum_#2 Drawing_E-3_R1

Replace: 557-2010 _Drawing_E-4 with 557-2010 _Addendum_#2 Drawing_E-4_R1