



759-2010 ADDENDUM 1

SEWPCC HEADWORKS UPGRADES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: October 19, 2010
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E4.18 (r)

Provide support to City personnel to commission the network communication to the sluice gate and suction valve actuators. Allow for eight (8) hours total for all actuators.

Revise: 26 05 34 Clause 2.3.1 to read:

PVC coated malleable iron spacers, CSA approved for the purpose.

Revise: 26 05 34 Clause 2.3.2 to read:

Aluminum channel may be utilized where conduits are grouped.

Delete: 26 05 34 Clause 2.3.3

Add: 26 05 34 Clause 3.2.12.5

Install spacers as required to provide a space between the conduits and the supporting surface, with a minimum space as follows:

1. Above grade spaces not classified as CEC Category 1 or 2:
 - .1 Drywall / Wood surfaces: no space required
 - .2 Masonry / concrete surfaces: 6 mm
2. Below grade spaces: 12 mm

DRAWINGS

Add: 759-2010_Addendum_1_Drawing_1-0102A-B0001-001-00

Add: 759-2010_Addendum_1_Drawing_1-0102A-B0002-001-00