
PEGIN Certificate of Authorization	
SNC-Lavalin Inc.	
No. 4489	


21mm AL CONDUIT —

FLOOR —

EXISTING PIPING AND —— LEVEL CONTROLLER



DEVICE SCHEDULE										
ITEM		1	MODEL							
1	FLOAT LEVEL SWITCH	FLYGT	ENM-10 WITH SUBMERSIBLE CABLE							
2	SUBMERSIBLE LEVEL TRANSMITTER, 4-20mA, 0 TO 15 mH <sub>2</sub> O	GE DRUCK	PTX 1290 WITH SUBMERSIBLE CABLE							



B DRY WELL - FLOOD LEVEL TRANSMITTERS

NTS

						SNC+LAVALIN	SNC-LAVALIN INC. 148 Nature Park Way Winnipeg, MB, Canada R3P 0X7 204-786-8080	ENGINEER'S SEAL
-						DESIGNED BY: T. CHURCH	CHECKED BY: C. REIMER	ORIGINAL DRAWING SEALED BY: T. CHURCH
-						DRAWN BY: S. COATES	APPROVED BY: C. REIMER	SNC-LAVALIN INC. 2010/10/01
						SCALE: NTS	BY: J. VEILLEUX 010/02/22 DATE: 2010/10/01	REV. 00
-	00	ISSUED FOR TENDER	2010/10/01	TMC		DATE: 2010/02/22  CONSULTANT NO.: 440577		
	NO.	REVISIONS	DATE	DESIGN	CHECK	112577-0112-48DD-0300		

Winnipeg THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE HEADWORKS UPGRADES INSTALLATION DETAILS SUMP LEVEL SWITCH & FLOOD LEVEL TRANSMITTERS

SHEET REV. SIZE OO1 OO A1 CITY DRAWING NUMBER 1-0102G-A0084

1-0102G-A0084-001-00.dwg