



766-2010 ADDENDUM 2

GARAGE DOOR RETROFIT AT 360 MCPHILLIPS STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: November 24, 2010
BY: Jim Lukashenko, P.Eng.
TELEPHONE NO. (204) 272-2025

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E6.1 to read: All salvaged material shall become the property of the Contractor unless specifically noted otherwise by the Contract Administrator, and shall be removed from the Site. The existing garage door motor, associated controls and associated mechanisms shall be salvaged and provided to the City undamaged.
- E15.2(e)(v) to read: Operation shall be chain hoist and electric operator connected to operable exterior mounted key switch and interior open/close/stop push button.
- Add: E15.2(e)(ix) Exterior mounted key switch complete with associated accessories and removable cylinder to be replaced with the Owner's cylinder. The exterior mounted key switch shall be connected to and operate with the new door and operator system.
- E15.2(e)(x) Interior open/close/stop push button and associated accessories to be connected to and operate with the new door and operator system.

DRAWINGS

- Replace: 766-2010 _Drawing_D-12272-R0 with 766-2010 _Addendum_2-Drawing_D-12272-R1
- 766-2010 _Drawing_D-12273-R0 with 766-2010 _Addendum_2-Drawing_D-12273-R1