



## 945-2010 ADDENDUM #3

### WINNIPEG FIRE PARAMEDIC ALTERNATIVE EMERGENCY CENTRE – INTERIOR RENOVATION AT 185 KING STREET – MAIN FLOOR

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: January 12, 2010  
BY: Kathy Roberts  
TELEPHONE NO. (204) 470-7380

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, January 17, 2011.

#### **PART E – SPECIFICATIONS**

Add:

##### **E14. ACOUSTIC CEILING TILE**

E14.1 Acoustic ceiling tile shall be CGC 2' x 4' x 5/8" SQ, Class A #562 "Fissured", with grid profile option #B.

##### **E15. VOICE AND DATA CABLING**

E15.1 Further to Drawing E-4, there are ten (10) CAT6 cables at the main work stations, and one (1) CAT6 cable per symbol at the other locations. Voice/data outlets will have two (2) cables each.

E15.2 Voice cable symbols have 1 cable each, and terminate at the data rack patch panel.

E15.3 New data cables will terminate at the new patch panels in the existing LAN room.

E15.4 Patch cables will be supplied by the City.