



966-2010 ADDENDUM 2

NEW FIRE PARAMEDIC STATION NO. 27, SAGE CREEK BLVD.

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 27, 2011
BY: Reid Douglas
TELEPHONE NO. (204) 986-3555

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- | | | |
|---------------|---------|---|
| Section 03300 | 2.1.13 | Add: CPD Non Shrink Grout as an approved equal. |
| Section 03300 | 2.1.18 | Add: SCP AcrI Stix Bonding Agent as an approved equal. |
| Section 04200 | | attached, was not included in error. |
| Section 07242 | 2.1.1 | Horizontal Application:
Add alternate acceptable manufacturer Owens Corning – Celfort 300, Type IV Insulation. |
| Section 07242 | 2.1.2 | Vertical Application:
Add alternate acceptable manufacturer Owens Corning – Celfort 300, Type IV Insulation. |
| Section 07530 | 2.1.2 | Add: “Genflex” as an approved equal. |
| Section 08213 | 2.1.1 | Add: “Lambton Doors” as an approved equal. |
| Section 08350 | 2.2.1 | Add: C.H.I. Overhead Doors, model 3295 as an approved equal. |
| Section 08350 | 2.3.11 | Revise line to read “...Mounting heights for the 4 (Four) Type ‘U’ ...”. |
| Section 08350 | 2.3.13 | Revise line to read “...All four (4) overhead doors...”. |
| Section 08360 | 2.1.1.1 | Delete line “Approx dimensions: refer to door schedule” and replace with “Refer to A8.1, Detail 1, Type F6: Overall dimension 2400 x 1400”. |
| Section 08410 | 2.1.2 | Delete: Ford Glass Limited, Lorlea Limited and PPG Industries.
Add: Alumicor to list of acceptable manufacturers. |

- Section 08710 Finish Hardware Schedule
Delete heading #11 & heading #16
- Section 08710 Finish Hardware Schedule - Auto Operator: Add "Gyro Tech 500 Heavy Duty" as an approved equal .
- Section 09300 2.1.1. Refer to types CT-1. Delete "Dark Grey Proposta 7, Random 5 tile pattern" and replace with "Mirage SL05 Grey, 4 tile pattern composed of: 12" x 12", 12" x 24", 18" x 18" & 6" x 6".
- Section 09300 2.1.8 Add new line Item: "Waterproofing: Schluter-Kerdi installed on all 3 wall surfaces, ceiling and floors within each shower stall. Schluter-Kerdi Band 185mm width to seal all butt joints and corner joints.
- Section 09650 2.1.2 Delete Material "Mondo Endurance Tile – Exercise Room" and replace with "Dinoflex Sport Mat – Interlocking System". Revise thickness from "3/8" to 10mm.
- Section 10800 2.1.3 Add new items: FLUERCO Products
1. Frameless Shower Doors - (2 required)
HINGED ON LEFT SIDE
- Platinum X, "Kara" Deluxe Glass 3/8" (10mm) tempered with polished edges.
Wall Mount Square Hinges - Bright Chrome
Straight Handle - Bright Chrome
(30" to 31" opening)
PXK30-11-40-TA
2. Frameless Shower Doors - (2 required)
HINGED ON RIGHT SIDE
- Platinum X, "Kara" Deluxe Glass 3/8" (10mm) tempered with polished edges.
Wall Mount Square Hinges - Bright Chrome
Straight Handle - Bright Chrome
(30" to 31" opening)
PXK30-11-40-TA
3. Frameless Panel and Door - (1 required)
HINGED ON LEFT SIDE
- Platinum X, "Kara" Deluxe Glass 3/8" (10mm) tempered with polished edges.
Wall Mount Square Hinges - Bright Chrome
Straight Handle - Bright Chrome
(47 1/4 to 48 1/4" opening)
PXKP47-11-40-TA
4. Frameless Panel and Door - (1 required)
HINGED ON RIGHT SIDE
- Platinum X, "Kara" Deluxe Glass 3/8" (10mm) tempered with polished edges.
Wall Mount Square Hinges - Bright Chrome
Straight Handle - Bright Chrome
(47 1/4 to 48 1/4" opening)

PXKP47-11-40

DRAWINGS

Replace 966-2010 Drawing A1-1-R4 with 966-2010 Addendum 2 Drawing A1-1-R5

Location of iron eagle fencing has been modified.

Replace 966-2010 Drawing A2-1-R4 with 966-2010 Addendum 2 Drawing A2-1-R5

Men's and Women's shower area has been modified to include concrete block fin walls at each shower stall opening.

Replace 966-2010 Drawing A7-1-R4 with 966-2010 Addendum 2 Drawing A7-1-R5

Re: Ceramic Wall Tile – Men's Washroom / Women's Washroom

1. Ceramic wall tile indicated on details 18, 19, 20 and 21 has been modified.
2. Ceramic wall tile indicated on details 22, 23, 24 and 25 has been modified

Replace 966-2010 Drawing A8-1-R4 with 966-2010 Addendum 2 Drawing A8-1-R5

Re: Room Schedule / Door Schedule

1. Room 111, North Wall changed from PT-1 to WCT 1 / 2 & PT-1.
1. Room 114, South Wall changed from PT-1 to WCT 1 / 2 & PT-1.
2. Door 111-3 remarks column changed to "glass door – refer to specification".
3. Door 111-4 remarks column changed to "glass door – refer to specification".
4. Door 111-5 remarks column changed to "glass door – refer to specification".
5. Door 114-3 remarks column changed to "glass door – refer to specification".
6. Door 114-4 remarks column changed to "glass door – refer to specification".
7. Door 114-5 remarks column changed to "glass door – refer to specification".

Replace 966-2010 Drawing LG-1-R2 with 966-2010 Addendum 2 Drawing LG-1-R3

Replace 966-2010 Drawing SS-1-R2 with 966-2010 Addendum 2 Drawing SS-1-R3

Add 966-2010 Addendum 2 Drawing SK2-2A-R0

Add 966-2010 Addendum 2 Drawing SK1-4A-R0

The above drawings refer to Structural Drawing S1.4 & S2.2

Re: HSS Size Revision

1. COLUMN SCHEDULE: Revise steel column size of C2 from HSS 203x203x8.0 to HSS 305x305x8.0 and revise its base plate size from 350x19x350 to 450x19x450 to coordinate with section detail.

Clarification for 966-2010 Drawing S1-1-R2

Re: Clarification (Slab on Grade vs Slab on Void)

200 Slab on grade is noted on S1.1 while structural detail shows void form. For clarification S1.1 should read slab on void.