

CIRCULATION PUMP SCHEDULE

| MARK | MAKE/MODEL | PUMP TYPE | SIZE | SERVES | FLOW | | HEAD | | MOTOR | | Voltage | DESIGN WEIGHT | | NOTES |
|------|----------------------|-----------------------------|----------|--------|------|-----|------|----|-------|-------|---------|---------------|-----|-------|
| | | | | | lpm | gpm | kPa | ft | kW | HP | | kg | lbs | |
| P-1 | B & G Series 1510 | End Suction Base Mounted | 2-1/2 BB | POOL | 1037 | 274 | 179 | 60 | 6 | 7 1/2 | 208/3 | 159 | 350 | 1,2,3 |
| P-2 | B & G Series 1510 | End Suction Base Mounted | 2-1/2 BB | POOL | 1037 | 274 | 179 | 60 | 6 | 7 1/2 | 208/3 | 159 | 350 | 1,2,3 |

1. Confirm voltage with electrical drawings.
2. Each pump supplies two sand filters in parallel.
3. Pumps for pool use. Pump to be supplied with wetted parts coated with appropriate epoxy coating.