



436-2011 ADDENDUM #1

PUMP REPLACEMENT AND UPGRADES, 444 ADSUM

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: June 3, 2011
BY: Kathy Roberts
TELEPHONE NO. (204) 470-7380

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

- Revise: D2.3 to read: All Work shall be done during a maintenance shutdown period, from August 28, 2011 to September 30, 2011.
- Revise: D13.1 to read: The Contractor shall achieve Substantial Performance by September 16, 2011.
- Revise: D14.1 to read: The Contractor shall achieve Total Performance by September 30, 2011.

PART E – SPECIFICATIONS

Revise: E1.7 to read: The following are applicable to the Work:

<u>Specification No.</u>	<u>Specification Title</u>
	Index to Specification
	Mechanical Equipment Schedules
15010	General Requirements
15050	Basic Materials & Methods
15070	Mechanical Vibration Isolation
15190	Identification
15700	Liquid Heat Transfer
15850	Testing & Balancing
<u>Drawing No.</u>	<u>Drawing Name/Title</u>
M-1 R3	MECHANICAL ROOM – PLAN AND SECTIONS
E-1 R3	MECHANICAL ROOM – ELECTRICAL WORKS
E-2 R4	ELECTRICAL SPECIFICATION

MECHANICAL SPECIFICATIONS

- 15050 Basic Materials and Methods
- Revise: 2.7.2 to read: Thermometers to be liquid-filled and shall have 125 mm (5") diameter dials. Use back or bottom inlet stems, whichever is best suited for ease of reading
- Revise: 2.8.2 to read: Pressure gauges to be liquid-filled, and shall have 125 mm (5") diameter dials. Gauges chosen with indicating needles at 12 o'clock position for normal operating pressure.

DRAWINGS

Replace: 436-2011 _Drawing_M-1 R2 with 436-2011 _Addendum_1_Drawing_M-1 R3
436-2011_Drawing_E-1 R2 with 436-2011_Addendum_1_Drawing_E-1 R3