



665-2011 ADDENDUM 1

Supply and Installation of Underground Fuel Storage Tanks and All
Associated Equipment at 552 Plinguet street

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 19, 2011
BY: Ajaleigh Williams
TELEPHONE NO. (204) 986-7879

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, September 22, 2011.

PART E – SPECIFICATIONS

Revise: E4.5.1 (a) (i) to read: Sub-base material shall be crushed sub-base material 50mm MAX.AGG. per TABLE CW3110.1. For bidding purposes, sub-base material shall be 450mm in thickness. Following award of the Contract, the Contractor shall take a core sample to determine the required thickness for the sub-base and shall receive the Contract Administrator approval on recommended thickness prior to proceeding with work. The City shall be billed for actual work conducted on the sub-base.