



778-2011 ADDENDUM 1

SUPPLY AND DELIVERY OF DC BATTERY BANK

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 21, 2011
BY: Curtis Reimer
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: B2.1 to read:

The Submission Deadline is 4:00 p.m. Winnipeg time, October 10, 2011.

Revise: E4.10.3 (h) to read:

Design life: 20 years in float service at 25°C.

Clarification of E4.10.4

The battery compartment shall be rated NEMA-1 while the battery charger compartment shall be rated NEMA-12.