



787-2011 ADDENDUM 1

REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR THE MACLEAN PUMPING STATION MCC REPLACEMENT DETAILED DESIGN AND CONTRACT ADMINISTRATION

ISSUED: September 27, 2011
BY: Linda McCusker, P.Eng.
TELEPHONE NO. (204) 986-6669

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL

THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Ar20070420

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B9.1 to read:

The Proposal shall include a **Fixed Fee** for all disciplines identified and necessary for the following Scope of Service phases of the Project:

- (a) Project Management (as defined in Section D4.4.1);
- (b) Detailed Design (as defined in Section D4.4.2).

Revise: B9.2 to read:

The Proposal shall include a fee schedule calculated on a **Time Basis** for all discipline identified and necessary for the following Scope of Services phases of the Project:

- (b) Contract Administration (as defined in Section D4.4.3).

PART D – SUPPLEMENTAL CONDITIONS

Revise: D4.3(i) to read:

Installation of a new 600-120/208V transformer for Lighting Panel B (PNL-B). Note that the City has already purchased the transformer.

Revise: D4.4.2(a) to read:

Collect and review all available existing information about the site including files, reports, drawings, etc. Detailed design to be based on the September 2011 "MacLean Pumping Station MCC Replacement Preliminary Design Revision 01" prepared by SNC Lavalin. Alternative designs will be considered but will require approval from the City.

Appendix B – RELEVANT DOCUMENTS

Revise: Item 1 to read:

The following document is available for viewing at 1199 Pacific Avenue through the Project Manager:

- SNC Lavalin (September 2011) MacLean Pumping Station MCC Replacement Preliminary Design, Revision 01