

Part 1 General

1.1 REFERENCES

- .1 American National Standards Institute (ANSI)
 - .1 ANSI/NFPA 10-2010, Portable Fire Extinguishers.
- .2 Underwriters' Laboratories of Canada (ULC)
 - .1 CAN/ULC-S508-2002 (R2007), Rating and Fire Testing of Fire Extinguishers and Class "D" Extinguishing Media.

1.2 SHOP DRAWINGS AND PRODUCT DATA

- .1 Submit shop drawings and product data in accordance with Section 01 33 00 - Submittal Procedures.

1.3 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

Part 2 Products

2.1 MULTI-PURPOSE DRY CHEMICAL EXTINGUISHERS

- .1 Stored pressure rechargeable type with hose and shut-off nozzle, ULC labelled for A, B and C class protection.
- .2 Sizes as indicated.

2.2 CARBON DIOXIDE

- .1 Extinguishers Insulated handle, hose and non-metal horn discharge assembly, self-closing lever or squeeze-grip operation, fully charged, ULC labelled for B and C class protection.
- .2 Sizes as indicated.

2.3 EXTINGUISHER BRACKETS

- .1 Type recommended by extinguisher manufacturer.

2.4 IDENTIFICATION

- .1 Identify extinguishers in accordance with recommendations of CAN/ULC-S508.
- .2 Supply and install an identification lamacoid adjacent to each fire extinguisher.
- .3 Attach tag or label to extinguishers, indicating month and year of installation. Provide space for service dates.

Part 3 Execution

3.1 INSTALLATION

- .1 Install or mount extinguishers in cabinets or on brackets as indicated.
- .2 Attach lamacoids with screws.

END OF SECTION