



299-2012 ADDENDUM 5

REQUEST FOR PROPOSAL FOR A DESIGN – BUILD – OPERATE OF A LANDFILL GAS PROJECT AT THE BRADY ROAD RESOURCE MANAGEMENT FACILITY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
REQUEST FOR PROPOSAL**

ISSUED: May 25, 2012
BY: Irvin Slike
TELEPHONE NO. (204) 806-0957

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE REQUEST FOR PROPOSAL AND
SHALL FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: Ar20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.4 to read:

D2.4 SWD-D-412 depicts the general location of three phase power, and the area of City property dedicated to Contractor's flare, material storage area, construction trailer, and flare control house. The City will provide the three phase **600** Volt and 400 amp service to the location in the drawing. The Contractor is responsible for permitting, connection construction and purchase of the power to operate the flare, and other Contractor's activities during the contract period.