

## 323-2012 ADDENDUM 2

### REQUEST FOR PROPOSAL FOR PROFESSIONAL CONSULTING SERVICES FOR THE PROVISION OF DETAILED DESIGN AND CONTRACT ADMINISTRATION SERVICES FOR THE RIVERGATE OUTFALL UPGRADES

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE REQUEST FOR PROPOSAL**

ISSUED: May 2, 2012  
BY: Kaz Zurek  
TELEPHONE NO. (204) 986-2025

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE REQUEST FOR PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Ar20120228

---

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Request for Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Proposal may render your Proposal non-responsive.

---

#### **PART E – SCOPE OF SERVICES**

Revise: E1.2 to read: General

- (a) The work shall be coordinated and planned in consultation with adjacent homeowners.
- (b) The following engineering services are required for the Rivergate Outfall:
  - (i) Structural engineering services for the design of the new gate chamber, complete with manhole & equipment hatches, ladders and shall be sized to accommodate one 2250 mm diameter flap gate and one 2250 mm diameter sluice gate (or positive gate).
  - (ii) Structural engineering services for the design of a new MH to be located upstream of the 2250mm LDS outfall gate chamber.
  - (iii) Provision of survey services to determine project limits, elevations and locations.
  - (iv) Condition assessment of existing 2250mm outfall pipe at proposed chamber location.
  - (v) Design of temporary by-pass operation.
  - (vi) Design of municipal services outside the outfall chamber, if required.
  - (vii) Provision of any geotechnical, soil testing and riverbank stability reports for use in design and obtaining required construction permits.
  - (viii) Preparation of Bid Opportunity documents.
  - (ix) Resident and non-resident Contract Administration services.
- (c) **The new gate chamber shall be located at the edge of pavement on the river side of the “Water Edge Condominium Complex”.**
- (d) The Department will provide assistance towards the following engineering services:
  - (i) Provision non-resident contract administration and inspection services for above.
  - (ii) Selection of the flap gate valve and positive gate valve.
  - (iii) Design of temporary by-pass operation.