



## 367-2012 ADDENDUM 1

### SHINGLE REPLACEMENT AT LINDENWOODS COMMUNITY CENTRE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY**

ISSUED: May 22, 2012  
BY: Norm Carrothers  
TELEPHONE NO. (204) 794-4400

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Revise: E2.6.1 to read: this shall be 22 gauge AD300 as manufactured by Vic West. Metal is to be pre-finished and is to be chosen from the standard in stock range of 10,000 series of colours.