



## 509-2012 ADDENDUM 1

### FORT ROUGE TRANSIT GARAGE - VEHICLE EXHAUST UPGRADE

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: July 20, 2012  
BY: Peter Gryc, SMS Engineering  
TELEPHONE NO. (204) 789-2346

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20120228

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART E – SPECIFICATIONS**

Section 15180, Add: 3.1.4.3

Provide 26 ga.G.I. sheet metal cover to protect insulation on the 3 existing fan installations shown on drawing M1.2. Repair the existing damaged aluminum foil insulation wrap to prevent water intrusion prior to applying the new cladding