







GENERAL NOTES

- A. ELECTRICAL SUB—CONTRACTOR TO VISIT SITE DURING BID AND VERIFY ALL EXISTING SERVICES ON SITE PRIOR TO SUBMITTING BID. REPORT ANY DISCREPANCIES TO CONTRACT ADMINISTRATOR DURING BID PERIOD.
- B. ELECTRICAL SUB—CONTRACTOR SHALL ENSURE COORDINATION BETWEEN ALL TRADES AND CONTRACT ADMINISTRATOR, ON AND OFF SITE, AS REQUIRED FOR INSTALLATION OF ELECTRICAL EQUIPMENT.

DEMOLITION KEY NOTES

- DISCONNECT AND REMOVE LIGHT SWITCHES AND CONDUIT, ETC NO LONGER REQUIRED FOR THE LIGHT FIXTURES. DELETE ALL CONDUIT AND WIRE BACK TO SOURCE.
- REMOVE JUNCTION BOX, CONDUIT, WIRE ETC. NO LONGER REQUIRED FOR LIGHT FIXTURES REMOVED DURING ASBESTOS ABATEMENT CONTRACT BACK TO SOURCE.
- REMOVE CONTACTOR BOX AND ASSOCIATED CONTACTORS, CONDUITS AND WIRING BACK TO SOURCE
- 4. ELECTRICAL SUB—CONTRACTOR SHALL TEMPORARILY SUPPORT ALL REMAINING CONDUITS FROM THE ROOF PRIOR TO THE REMOVAL OF THE EXISTING CEILING FRAME. REMOVE AND REPLACE CONDUITS AND WIRE AS NECESSARY TO FACILITATE CEILING REMOVAL.

