DRAWING INDEX

SHEET NUMBER	CITY OF WINNIPEG DRAWING NUMBER	DRAWING TITLE
1	D-13024	DRAWING INDEX
2	D-13025	RUE BOURGEAULT - RUE DESCHAMBAULT TO CABANA PLACE
3	D-13026	BROOKLYN STREET - PORTAGE AVENUE TO 100 N OF PORTAGE AVENUE
4	D-13027	BROOKLYN STREET - 100 N OF PORTAGE AVENUE TO 225 N OF PORTAGE AVENUE
5	D-13028	EDISON AVENUE - ROCH STREET TO 75 E OF ROCH STREET
6	D-13029	EDISON AVENUE - 75 E OF ROCH STREET TO 200 E OF ROCH STREET
7	D-13030	KINGSTON ROW - 18.5 N OF ROSEWARNE AVENUE TO 195 N OF ROSEWARNE AVENUE
8	D-13031	WAVERLEY STREET - GRANT AVENUE TO 75 N OF GRANT AVENUE
9	D-13032	WAVERLEY STREET - 75 N OF GRANT AVENUE TO 200 N OF GRANT AVENUE

ABBREVIATIONS

wws	WASTE WATER SEWER	
cs	COMBINED SEWER	
LDS	LAND DRAINAGE SEWER	
MH	MANHOLE	
PL	PROPERTY LINE	
Ę.	CENTER LINE	
G.I.S.	GEOGRAPHIC INFORMATION SYSTE	
B.M.	BENCH MARK	
TH	TEST HOLE	
ELEV	ELEVATION	
INV	INVERT	
MIN	MINIMUM	
SL	STREET LIGHTING	
TS	TRAFFIC SIGNALS	
ABAND	ABANDONED	
BLDG	BUILDING	
HSE	HOUSE	
c/s	CURB STOP	
MTS	MANITOBA TELEPHONE SYSTEM	
R.O.W.	RIGHT-OF-WAY	
WM	WATERMAIN	
CULV	CULVERT	
MH	MANHOLE	
СВ	CATCH BASIN	
а	CURB INLET	
VERT.	VERTICAL	
HORZ.	HORIZONTAL	
I.B.	IRON BAR	
FIBRE	FIBRE OPTIC	
X-ING	CROSSING	
HYD	HYDRANT	
EXIST	EXISTING	

LEGEND

	PLAN VIEW	
DESCRIPTION	EXISTING	PROPOSED
WATER PIPE		
FIRE HYDRANT		+
VALVE CURB STOP	⊗	o *
REDUCER	4	•
COUPLING OR SLIDDER	x	x
CROSS	•	⊕
BEND - 11.25', 22.5', 45', 90'	4 4 4 A	н 4 4 ч н
TEE VERTICAL BEND	н	н
ANODE		5
REPAIR MARKER	♥	
PLUG	1	1
SEWER PIPE MANHOLE		— <u>;</u> —
CATCH BASIN		
CURB INLET	_ ▽	₹
JUNCTION		
€ DITCH	→ → −	→ → −
CULVERT SURVEY BAR	# #	c======
SURVEY MONUMENT	*	*
TREE - DECIDUOUS	Č	•
IREE - DECIDOOS	بن	
TREE - CONIFEROUS		
HYDRO		
HYDRO POLE	•н	
LAMP STANDARD	••	
HYDRO POLE W/STREET LIGHTING	He-e	
POLE	· ·	
GUY ANCHOR M.T.S. POLE	←	
PEDESTAL OR BOX	•м ⊠	
CABINET	\bowtie	
M.T.S.		_··-
TRAFFIC SIGNALS TRAFFIC LIGHT STANDARD		
GAS		
STEAM		
FIBRE OPTIC		
FENCE	xx	xx
EDGE OF PAVEMENT OR GUTTER		
EDGE UNPAVED OR GRAVEL ROAD		
PROJECTED R		
LOT LINE		
SIDEWALK - PATHWAY		
EASEMENT		
EDGE OF BUILDING		
MAILBOX	M	
TEST HOLE	*	•
TREE LINE OR BUSH	~~~~	
	PROFILE	
DESCRIPTION	EXISTING	PROPOSED
WATER PIPE		
HYDRANT TOP	+	+
VALVE	X	X
TEE OR CROSS		
COUPLING OR BEND		
REDUCER		
END OF PIPE	8	8
SEWER PIPE	·	
		-
UNPAVED GROUND SURFACE	- MARIN MARIN	
PAVED GROUND SURFACE - & PIPE	xx	
GUTTER (NORTH AND WEST)		
GUTTER (SOUTH AND EAST)	—————————————————————————————————————	
© DITCH (NORTH AND WEST) © DITCH (SOUTH AND EAST)	<u> </u>	
STRUCTURE		
	1	1
	į	i
MANHOLE OR CATCH BASIN		

CONSTRUCTION NOTES

- 1. EXPOSE EXISTING WATERMAIN & CONFIRM INVERTS PRIOR TO CONSTRUCTION.
- 2. LOCATION OF ALL SERVICES TO BE CONFIRMED IN THE FIELD.
- 3. INSTALL WATERMAIN BY TRENCHLESS METHODS.
- 4. TRENCHES AND EXCAVATIONS WITHIN 1 METRE OF A PAVED AREA INCLUDING SIDEWALKS SHALL BE CLASS 3 BACKFILL.
- 5. ALL MATERIALS SHALL CONFORM TO THE CITY OF WINNIPEG STANDARD CONSTRUCTION SPECIFICATIONS.
- 6. MINIMUM COVER TO TOP OF WATERMAIN SHALL BE 2.4 m.
- 7. REPLACE ALL EXISTING LEAD SERVICES FROM PROPOSED WATERMAIN TO $\ensuremath{\text{R}_{\star}}$
- 8. NOTIFY ALL AFFECTED RESIDENTS AND BUSINESSES 24 HOURS IN ADVANCE OF ANY WATER SHUTDOWNS OR DISRUPTION OF SERVICE.

EXISTING



HATCH PATTERNS

PROPOSED







INTERLOCKING STONE

CONCRETE

DESCRIPTION

EARTH OR GROUND ABOVE PIPE

SAND OR OTHER FINE MATERIAL

WASHED STONE OR GRANULAR MATERIAL

LOCATION APPROVED UNDERGROUND STRUCTURES COSTRUCTION COMPLETION DATE: YYYY MM DD ORIGINAL SIGNED SC APPROVED BY ΚZ RELEASED FOR CONSTRUCTION

DATE BY DATE 2012 04 18

BY S.R.J. COURNOYER 12-07-30

Winnipèg

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION

2012 WATER RENEWALS

SHEET 1 OF 9

INDEX PAGE

D-13024