



## 654-2012 ADDENDUM 2

### HVAC AND ELECTRICAL UPGRADES AT 552 PLINGUET STREET WASTEWATER SERVICES GARAGE AND ADJACENT BUILDINGS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: September 6, 2012  
BY: Daniel McLarty  
TELEPHONE NO. (204) 477-6650

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20120228

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART A – BID SUBMISSION**

Replace: 654-2012 Bid Submission with 654-2012 Addendum 2 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R1): Add Item No. 13.

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, September 14, 2012.

Revise: B3.1 to read: Further to C3.1, the Contract Administrator or an authorized representative will be available at the Site on August 30, 2012 at 2:00 PM and on September 11, 2012 at 2:00 PM to provide Bidders access to the Site.

#### **DIVISION 23 – SECTION 23 05 00**

Revise: 3.2.3 to read: Vacuuming of interior of ductwork and air handling units will be required if the air handlers are used during construction without acceptable construction filters in place or if duct opening have not been sealed during construction, to protect unit and ductwork from construction dust contamination.