



839-2012 ADDENDUM 3

CONSTRUCTION OF THE BRADY ROAD RESOURCE MANAGEMENT FACILITY LEAF AND YARD WASTE AND PILOT BIOSOLIDS COMPOSTING FACILITY

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: March 5, 2013
BY: Barry Williamson, P.Eng.
TELEPHONE NO. (204) 488-2214

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 839-2012 Bid Submission with 839-2012 Addendum 3 - Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

Form B(R2): Added granular quantities under Item 2 and Item 10

Revised Item numbers to reflect insertion of Biosolids Pad and Access Granular Quantities

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.2.f.xviii: Construction of Ditch #4 as shown on the drawings.

PART E – SPECIFICATIONS

SECTION 01010 – SUMMARY OF WORK

1.01 WORK COVERED BY CONTRACT DOCUMENTS

A.3. BIOSOLIDS FACILITY

Add: 16) Construction of Ditch #4 as shown on the drawings.

SECTION 15200-02 – HDPE PIPE AND FITTINGS DATA SHEET

Revise Bolting to Read: ASTM A193/A193M, Type 316 stainless steel, Grade B8M hex head bolts and ASTM A194/A194M Grade 8M hex head nuts.

SECTION 15200-03 – POLYVINYL CHLORIDE (PVC) PIPE AND FITTINGS

Revise Bolting to Read: All Flanges: ASTM A193/A193M, Type 316 stainless steel, Grade B8M hex head bolts and ASTM A194/A194M Grade 8M hex head nuts.

Delete: With Raised Face Mating Flange: Carbon steel ASTM A307 Grade B square head bolts and ASTM A563 Grade A heavy hex head nuts.

SECTION 16440 – LOW-VOLTAGE MOTOR CONTROL

2.05 MOTOR CONTROL CENTERS

Revise G.3.c to Read: Insulated or molded case breakers with ground fault protection.

Delete G.3.d, e, f.

Delete G.5

DRAWINGS

Replace: 839-2012 _Drawing_1-0400B-C0001-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0001-001-R1
839-2012 _Drawing_1-0400B-C0003-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0003-001-R1
839-2012 _Drawing_1-0400B-C0004-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0004-001-R1
839-2012 _Drawing_1-0400B-C0005-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0005-001-R1
839-2012 _Drawing_1-0400B-C0006-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0006-001-R1
839-2012 _Drawing_1-0400B-C0009-002-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0009-002-R1
839-2012 _Drawing_1-0400B-C0011-001-R0 with 839-2012 _Addendum_3 Drawing _1-0400B-C0011-001-R1
839-2012 _Drawing_1-0400B-E0002-001-R0 with 839-2012 _Addendum_3 Drawing_1-0400B-E0002-001-R1
839-2012 _Drawing_1-0400B-E0005-001-R1 with 839-2012 _Addendum_3 Drawing_1-0400B-E0005-001-R2
839-2012 _Drawing_1-0400B-E0006-001-R1 with 839-2012 _Addendum_3 Drawing_1-0400B-E0006-001-R2