



864-2012 ADDENDUM 3

REPLACEMENT OF A 1200 MILLIMETRE GATE VALVE AND STRUCTURAL MODIFICATIONS AT WILKES RESERVOIR VALVE PIT 'B'

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 4, 2013
BY: Rob Carroll, P.Eng
TELEPHONE NO. (204) 986-8409

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The submission deadline is 12:00 noon Winnipeg time, February 7, 2013.

PART E – SPECIFICATIONS

- Revise: E4.4.1(b) to read: The City will disconnect the power and control cabling from the existing valve and actuator.
- Revise: E4.4.1(c) to read: Remove and dispose of the existing valve, actuator and spool piece.
- Add: E4.4.1(d) The estimated weight of the existing valve is approximately 13,600 kg (30000 lb).
- Revise: E4.4.2(e) to read: The City will reconnect the power and control cabling to the new valve and actuator.
- Add: E5.1.4(b) Grout for the Floor Hatch shall be a cementitious pre-bagged non-shrink sand cement grout with a minimum 5000 psi (35 MPa) strength. If the space to be filled is over 75 mm then pea gravel aggregate may be required. Aluminum components of the hatch immersed in the grout shall be coated with a bituminous coating.
- Add: E5.3.7(a)(i) The insulation material is moulded expanded polystyrene.
- Add: E5.3.8(c) Excavations shall be backfilled using same earth or similar material. A minimum of 0.6 m earth cover above the valve chamber is required.