



12-2013_ADDENDUM_3

MARGARET GRANT POOL INTERIOR RENOVATIONS – 685 DALHOUSIE DRIVE

ISSUED: February 27, 2013
BY: Laurene Bachand
TELEPHONE NO. (204) 947-1100

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20120228

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

SECTION 09 30 13

Revise 2.2.1 Base: Create 4" base with floor tile. Grout lines to align with floor. Refer to Colour and Material Schedule and Room Finish Schedule.

SECTION 23 36 00

Revise 2.2.5 Acceptable Product: "EH Price" Model: LGB c/w ATT Attenuator Section per schedule below:

VAV No.	Design Airflow Rates		VAV Capacity		Make	Model		
	min (CFM)	max (CFM)	min (CFM)	max (CFM)				
VAV-1	208	520	0	700	EH Price	LGB	8	c/w 36" Attenuator & 1 Row Heating Coil
VAV-2	128	320	0	400	EH Price	LGB	6	c/w 36" Attenuator only
VAV-3	80	200	0	400	EH Price	LGB	6	c/w 36" Attenuator & 1 Row Heating Coil
VAV-4	64	160	0	400	EH Price	LGB	6	c/w 36" Attenuator & 1 Row Heating Coil
VAV-5	144	360	0	400	EH Price	LGB	6	c/w 36" Attenuator & 1 Row Heating Coil
VAV-6	48	120	0	400	EH Price	LGB	6	c/w 36" Attenuator only
VAV-7	48	120	0	400	EH Price	LGB	6	c/w 36" Attenuator only
VAV-8	184	460	0	700	EH Price	LGB	8	c/w 36" Attenuator & 1 Row Heating Coil
VAV-9	48	120	0	400	EH Price	LGB	6	c/w 36" Attenuator only
VAV-10	160	400	0	700	EH Price	LGB	8	c/w 36" Attenuator & 1 Row Heating Coil
VAV-11	80	200	0	400	EH Price	LGB	6	c/w 36" Attenuator