



419-2013 ADDENDUM 1

WEWPCC POWER FACTOR CORRECTION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 9, 2013
BY: Tim Church
TELEPHONE NO. (204) 786-8080

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Add: E3.3 (c) (i)

While the switchgear is shutdown, use an ohmmeter to determine if the secondary circuits of the existing CTs are grounded. If not adequately grounded, provide a new ground wire connection to the CT shorting terminal bar in the switchgear control cabinet.

Add: 26 35 33 2.1.12

The ABB CLMR Capacitor Bank Series was utilized as a reference during the preparation of this Bid Opportunity.