



594-2013 ADDENDUM 1

PEGUIS PAVILION POND RENOVATIONS AND LANDSCAPING

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: 2014-08-06
BY: David Anderson, P.Eng.
TELEPHONE NO. (204) 896-1209

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, **August 13th, 2014**

PART E – SPECIFICATIONS

Revise: E23.3.2 to read: The drain line will be measured on a length basis and paid for at the Contract Unit Price for "Drain Line". The length to be paid for shall be the total number of lineal metres of Drain Line supplied and installed in accordance with the Purchaser's Drawings. The prices shall be full payment for supplying all labour, equipment and materials, **including pipe ballast, as indicated on drawing C01 R1**, and performing all operation including excavation, subgrade preparation, backfill, compaction, supply and installation of drain line and all other items incidental to the Work for "Drain Lines" and accepted by the Contract Administrator.

Add: E23.3.5 (a) The sump pump shall be a ½ HP, 115v Zoeller M98, or 120v Barnes SP50VFX, or an Approved Equal as per B7, and as indicated on Drawing C01

DRAWINGS

Replace: 594-2013_Drawing_C01-R0 with 594-2013_Addendum_1-Drawing_C01-R1