



634-2013 ADDENDUM 1

REGENT AVENE WEST TREE VAULTS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 18, 2013
BY: Shauna Prociuk
TELEPHONE NO. (204) 986-3938

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E11.1.1(a) to read: pre-cast concrete sidewalk panel – plain concrete finish to match concrete sidewalk finish and with inset galvanized hardware to facilitate lifting. Hardware to be covered with flush durable cover coloured to match concrete or approved equal. Pre-cast concrete panel to accommodate AASHTO H-20 loading. Manufacturer to supply shop drawings stamped by a structural engineer.