



714-2013 ADDENDUM 1

PROVISION OF LABORATORY TESTING FOR CITY POOLS

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: September 9, 2013
BY: Glen Konowalchuk
TELEPHONE NO. (204) 986-2249

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20130301

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Add: D2.4

Specific methods of laboratory testing must be accomplished according current applicable Province of Manitoba Regulations. The "Swimming Pools and Other Water Recreational Facilities Regulation" stipulates that the membrane filtration technique is the required method of determining total coliform & Pseudomonas in pools and whirlpools.

This regulation can be found through the following link:

<http://web2.gov.mb.ca/laws/regs/pdf/p210-132.97.pdf>