



**AUBREY WASTEWATER PUMPING STATION UPGRADE**

**URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: July 8, 2014  
BY: Rudy Derksen  
TELEPHONE NO. (204) 478-3246

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20131129

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.**

---

**PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg Time, July 17, 2014.

Add: B3.1(b) An additional site visit opportunity will be offered at 11:00am on Thursday July 10, 2014.

**PART E – SPECIFICATIONS**

Revise: E28.2.3(a) to read: Size: 250mm

Revise: E28.2.3(h) to read: Lining: Teflon

Revise: E28.2.6(b) to read: Endress & Hauser Promag 50P with remote transmitter

Revise: E29.1(a) to read: Supply and install a 1.5 ton rated hoist as per Section E22.

Revise: E31.1.7 to read: Disconnect existing flood pump station supply cable from existing CSTE and remove it from the site.