

AUBREY WASTEWATER PUMPING STATION UPGRADE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 14, 2014
BY: Rudy Derksen
TELEPHONE NO. (204) 478-3246

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E22.1(f) to read: Preparation and painting of the new concrete block blast wall. Paint the concrete block blast wall the same as the pumphouse exterior walls.

Section 22 10 10

Revise Clause 2.1.3.1 to read: Pump Tags: SP-L51 and SP-L52

Section 26 24 02

Revise Clause 2.1.4 to read: Cubicles: Pad mounted Type 3R or Type 4 enclosure, main breaker compartment to be service entrance rated.

Add Clause 2.1.14: Incoming service conductors to be terminated in a separate compartment with a barrier from all adjoining sections, complete with a bolt on cover over incoming cable terminations inside a padlockable exterior door. Provide a lamacoid label on exterior of door to indicate dangerous arc flash level within.

DRAWINGS

Replace: 768-2013_Drawing_1-0116L-M0006-001-R0 with 768-2013_Drawing_1-0116L-M0006-001-R1

Replace: 768-2013_Drawing_1-0116L-E0001-001-R0 with 768-2013_Drawing_1-0116L-E0001-001-R1

Replace: 768-2013_Drawing_1-0116L-E0008-001-R0 with 768-2013_Drawing_1-0116L-E0008-001-R1