


- NOTES:**
1. YARD LIGHTING, CONVEYING AREA LIGHTING AND INTERIOR LIGHTING IN SAND & SALT AND SALT STORAGE AREA WILL USE 347V LIGHTING FIXTURE DUE TO THE VOLTAGE DROP CONCERN.
 2. THE REST AREA OF THE BUILDING WILL USE 120/208V SYSTEM.

SITE PLAN
 Scale 1:500
 0 12.5 25 m



ISSUE/REVISION

I/R	DATE	DESCRIPTION
0	13/12/12	ISSUED FOR BID OP. 838-2013
A	13/03/18	ISSUED FOR REPORT

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. All measurements must be obtained from stated dimensions.