


- NOTES:**
- SAND AND SALT FACILITY IS CLASSIFIED AS CATEGORY 2 AS PER CANADIAN ELECTRICAL CODE.
  - ALL ELECTRICAL EQUIPMENT AND DEVICES INCLUDING LIGHTING FIXTURES, MOTION SENSORS, SWITCHES, RECEPTACLES, CCTV CAMERAS AND CONTROL PANEL INSTALLED IN THIS FACILITY SHALL MEET CATEGORY 2 REQUIREMENTS.



**FLOOR PLAN**



**PROJECT**  
 Public Works East  
 Yards  
 Sand/Salt Facility

**CLIENT**  
 City of Winnipeg  
 Planning Property  
 and Development  
 Department  
 Municipal  
 Accomodations  
 Division

4th Floor - 185 King Street  
 Winnipeg, MB R3B 1J1

**CONSULTANT**  
 AECOM  
 99 Commerce Drive  
 Winnipeg, Manitoba, Canada R3P 0Y7  
 204.477.5381 tel 204.284.2040 fax  
 www.aecom.com

**REGISTRATION**

**ISSUE/REVISION**

I/R	DATE	DESCRIPTION
0	13/12/12	ISSUED FOR BID OP. 838-2013
A	13/03/18	ISSUED FOR REPORT

**LEGEND**

**PROJECT NUMBER**  
 60287880

**SHEET TITLE**  
 ELECTRICAL  
 FLOOR PLAN  
 CATEGORY CLASSIFICATION

**SHEET NUMBER**  
 E-1002

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for use by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent. Do not scale this document. All measurements must be obtained from stated dimensions.