



1068-2014 ADDENDUM 1

Water Treatment Research and Process Optimization Facility Mechanical and Electrical Construction Services

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 12, 2015
BY: Kelly Griffiths
TELEPHONE NO. (204) 488-2214

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20131129

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART D – SUPPLEMENTAL CONDITIONS

Revise E2. COMPONENTS OF WORK:

- Add: E2.2 (u) Exhaust fans and a fume hood will be supplied and installed under contract 85-2015. The electrical work associated with the installation will be completed under this Contract and includes the following:
- (i) Supply and installation of 15A – 1P, 120 VAC circuit breaker in panel PNL-X902, circuit 35,
 - (ii) Wiring and connecting fume hood located in the control room/lab, and
 - (iii) Wiring and connecting exhaust fans EF-X606, EF-X607, EF-X608, and EF-X609 from manual motor starters to fans.