



## 1068-2014 ADDENDUM 2

### Water Treatment Research and Process Optimization Facility Mechanical and Electrical Construction Services

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: February 20, 2015  
BY: Kelly Griffiths  
TELEPHONE NO. (204) 488-2214

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20131129

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 The Submission Deadline is 4:00 p.m. Winnipeg time, March 3, 2015.

#### **PART D – SUPPLEMENTAL CONDITIONS**

##### **Revise D10. INSURANCE:**

Revise: D10.1 (c) All risks course of construction insurance in the amount of one hundred percent (100%) of the total contract price, including testing and commissioning, to be written in the name of the Contractor and The City of Winnipeg, at all times during the performance of the Work and until the date of Total Performance.

#### **DRAWING**

Replace: 1068-2014\_DRAWING\_1-0601X-M0005-001-01-R1 with 1068-2014\_ADDENDUM\_2\_DRAWING\_1-0601X-M0005-001-02-R2

Ozone columns can be constructed out of 200 mm Schedule 40 clear PVC, as 200 mm Schedule 80 clear PVC is not commercially available.