



1145-2014 ADDENDUM 1

ALTERATIONS TO WATER CIRCULATION AND TREATMENT SYSTEMS FOR BROADWAY PARK WADING POOL – 185 YOUNG STREET

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: January 22, 2015
BY: Lou Chubenko
TELEPHONE NO. (204) 986-2727

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20150105

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Under SECTION 11240 VALVES:

Add 2.9.5 The Contractor shall be responsible for providing and installing Watts 9D backflow preventers on all sample taps (STP-101, STP-102, STP-103).