



# 1149-2014 ADDENDUM 1

## POOL TANK WALL MEMBRANE AND TILE REPLACEMENT FOR CONCORDIA ELMWOOD KILDONAN POOL – 909 CONCORDIA

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: December 10, 2014  
BY: Anh T. Duong  
TELEPHONE NO. 204-986-7588, 204-391-0872

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20130301

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, December 16, 2014

### **PART E – SPECIFICATIONS**

- Revise: E1.3(b) to add: Dust control system shall consist of a hoarding system for the entire pool tank area;
- Revise: E1.3(c) to read: Remove existing tiles on all pool walls (allowing maximum of 18” removal of tiles on floor perimeter), including wall nosing tiles;
- Revise: E1.3(e) to add: The water proofing system shall be used for the entire pool walls area;
- Revise: E1.3(f) to read: Supply & Install new tiles for walls using 2 inch tile, new nosing tiles, and new 1 inch tile for floor perimeter, tile colour to match existing (sample to be submitted for approval);
- Revise: E1.3(h) to add: Contractor to submit the marking plan as required for approval prior to awarding;